

October 4, 2005

NEUMAN POOLS INC  
KERRY A. BEECHER  
W9864 BEAVERLAND PKWY  
PO BOX 413  
BEAVER DAM WI 53916

Re: Description: POOL  
Manufacturer: NEUMAN POOLS INC  
Product Name: MILWAUKEE BUCKS TRAINING FACILITY/COUSINS CENTER  
Model Number(s): VITA SPA AND CAL SPA  
Product File No: 20050751

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an experimental approval to s. Comm 90.19 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2010.

This experimental approval is contingent upon compliance with the following stipulation(s):

- The pools shall be drained in accordance with the schedule proposed in the plan submittal.
- Both vacuum sensor switches shall be tested whenever the pools are drained. The test shall be run by intentionally closing the outlets from the pool. The test is successful if the vacuum switch cuts the power to the corresponding pump.
- Operation, maintenance, testing and reporting instructions shall be posted at the installation prior to final inspection sign off.
- A record shall be kept of all tests and maintenance performed. The record shall be available to Department of Commerce or Department of Health and Family Services personnel or agents.
- A record shall be kept of any injuries sustained while using the hot or cold pool. The record shall be available to the Department of Commerce or Department of Health and Family Services personnel or agents.
- The records required for this experiment shall be submitted to the Department of Commerce and the Department of Health and Family Services by July 1, 2006.
- The experiment is designed to evaluate code equivalence for the following items:
  1. Drains located in the side of the pool basin.
  2. Vacuum cartridge filters and their effectiveness.
  3. Transfer walls located at an elevation proposed to be appropriate for a basketball team.
  4. The draining schedule proposed by the designer.
  5. The cyanuric acid accumulation in small cold and hot vessels.
  6. If the opportunity arises, the rescue appropriateness of the reduced and elevated deck.

NEUMAN POOLS INC

Page 2

October 4, 2005

- If at any time the pool operator fails to comply with the requirements of this approval, experiment shall be discontinued immediately.
- This experimental approval expires on June 15, 2006. At that time the pools shall be made code compliant prior to their use.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

James H. Miller

Section Chief, Bureau of Integrated Services

Phone: 608-266-8072 Fax: 608-267-956